



Defence Fire Safety Services

Add- F-44, Yashwant Plaza, Indore

Contact: 7898003673 Email: -defencefiresafetyservices@gmail.com

REFILLING CERTIFICATE OF FIRE EXTINGUISHER

Certificate No: DFS/APRIL/2023

M/s Principal Kendriya Vidhyalay No-1

Address: Indore, M.P

This is to Certify that we have carried out the Refilling & Services of Following

Fire Extinguisher and also include maintenance, repairs/change of damage parts at the time of service of fire extinguisher as warranty period of 1 year from the date of refilling and also free from any manufacturing defects that properly maintained.

Sr. No	Type	Material	Capacity	Cylinder Sr. No	Work	Remark
1	ABC Powder	Mono Ammonium Phosphate + N2 Gas	6 KG	10 Nos.	Refill & Service	OK
2	WATER CO2	WATER+AFF+ N2 Gas	9 LTR	03 Nos.	Refill & Service	OK
Total Refilled Fire Extinguisher						13 Nos.

Note- if in case yellow seal of fire extinguisher found damage/broken warranty will be effect. or it will be laps.

Further we are certifying that the above equipment's are now in good working condition but necessary periodical maintenance and service is required to put in smooth working at all the time.

Issued Under Fire Protection

Tested & Issued by

Manual's Clauses No. 1,3,4 & 5.

For Defence Fire Safety Services

Refill Date: 16/04/2023

Next Refill Due Date: 15/04/2024

AUTHORISED SIGNATORY

