

Amrit

14/12/24

Water Testing Laboratory

Indore Municipal Corporation, Musakhedi, Indore

Email:- Amritindore@gmail.com, waterlabimc@outlook.com, Phone No.: 0731-2712842

NO:/QM/IMC/M/2023-24/Indore

Date 09.02.24

✓ To,

The Principal
Kendrya Vidhyalaya No.2
Indore (M.P)

Subject: Test Report of Water samples.

Reference: Your letter No. 5-1/K.V.-1

Date

2023-24/1050
10-01-24

Please find enclosed herewith report of water samples/invoice/Money receipt of sample/samples received for analysis as per the letter under reference.

Enclosures: As above

Quality Manager
Water testing Laboratory
Musakhedi, IMC, Indore

Copy to: Chief Executive Office (Laboratory), Maintenance Div. No. 2 I.M.C. information please.

Enclosures: As above


Sd/-
Quality Manager
Water testing Laboratory
Musakhedi, IMC, Indore

Water Testing Laboratory
Indore Municipal Corporation Musakhedi Indore (MP) India

Test Report

Lab Reference No CH/24/19	Report Page No. 1	Date	16.01.2024
To, The Principal Kendriya Vidhyalaya No. 1		Date of Receipt	16.01.2024
		Date of Commencement	16.01.2024
Sample Label :- Kendriya Vidhyalaya No. 1, Indore (M.P.)		Date of sample Collection If specified	-
		Volume of sample	5 lit.

S.No.	Characteristic	Method of Test ref. to	IS-10500-2012		Result
			Requirment Acceptable Limit	Permissible Limit in abesent of alternative Source	
1	pH Value	IS 3025 (Part- 11): 2022	6.5-8.5	No Relaxation	7.71
2	Colour,Hazen Unit, max	IS 3025 (Part 4) Clause no. 4: 2021	5	15	1
3	Odour	IS 3025 (Part- 05): 1983	Agreeable	Agreeable	Agreeable
4	Taste	IS 3025 (Part - 07): 1984	Agreeable	Agreeable	Agreeable
5	Turbidity,NTU, Max	IS 3025 (Part 10): 1984	1	5	1.83
6	Total Dissolved Solids mg/l, max	IS 3025 (Part 16): 1984	500	2000	394
7	Total Hardness (as CaCo3) mg/l, Max	IS 3025 (Part 21) Clause no. 5-5.7: 2009	200	600	274.4
8	Chloride (as CL) mg/l Max	IS 3025 (Part 32)- Clause no. 2: 1988	250	1000	62
9	Total Alkalinity (as CaCo3) mg/l,Max	IS 3025 (Part 23) Clause no. 4-9: 1986	200	600	290
10	Nitrate (as No3) mg/l Max	IS 3025 (Part 34) Clause no. 3.3: 1988	45	No Relaxation	-
11	Free Residual Chlorine mg/l,Min	IS 3025 (Part 26) Clause no. 5: 2021	0.2	1	Nil
12	Ammonia (as total ammonia -N), mg/l , max	IS 3025 (Part - 34), Clause no. 2.0: 1988	0.5	No Relaxation	-
13	Fluoride(as F) mg/l, Max	IS 3025(Part 60) Clause no. 6: 2008	1	1.5	-
14	Iron(as Fe) mg/l, Max (VCM)	IS 3025 (Part - 53), Clause no. 06: 2023	1	No Relaxation	-
15	Calcium(as Ca) mg/l, Max	IS 3025 (Part 40) : 1991	75	200	-
16	Magnesium(as Mg) mg/l, Max	By culcation	30	100	-
17	Sulphate(as So4) mg/l, Max	IS 3025 (Part 24) Section 1- 2022	200	400	-
18	Total Coliform Bacteria	IS 1622 - 1981	ND	ND	-
19	Fecal Coliform Bacteria	IS 1622 - 1981	ND	ND	-
20	C.O.D. Test	-	-	-	-


Mr. Manish Thacker
Technical Manager
Chemist

Water Testing Laboratory
Indore Municipal corporation, Musakhedi,
Indore (M.P.)

Date

Proforma Invoice

To,
The Principal
Kendriya Vidhyalaya No. 1,
Indore (M.P.)

Rate applica-ble Govt./ Prt.

S.no.	Test	# Rate Per Test		Rate applica-ble	Rate	Amount
		For Public & Govt. Concern	For Commercial Concern			
NABL Accreditate Test Parameter						
1	Color	100	250		1	100
2	Odour test	100	250		-	-
3	Turbidity	100	250		1	100
4	pH	100	250		1	100
5	Alkalinity	100	250		1	100
6	Total Hardness	150	375		1	150
7	Ammonia	100	250		-	-
8	Nitrate	100	250		-	-
9	Total Solid test/ Dissolved Solid	150	375		1	150
10	Residual Chlorine	150	250		1	150
11	Fluoride	150	250		-	-
12	Iron	150	250		-	-
13	Taste	150	375		-	-
Non Accreditate Test Parameter						
14	Calcium	150	250		-	-
15	Magnesium	80	200		-	-
16	Chloride	100	250		1	100
17	Nitrite	100	250			
18	Sulphite test	150	375			
19	B.O.D. test	150	375		-	-
20	C.O.D. test	150	375		-	-
21	Phosphate test	150	375		-	-
22	Sulphate	150	375		-	-
23	Dissolved Oxygen test	150	375		-	-
24	Total Coli form (MPN)	200	500		-	-
25	Bleaching Powder/hypo	100	250		-	-
Total =	Rs. Nine Hundred Fifty Only					950

*# Rate applicable w.e.f 30/5/96 as per letter 2029/TS maint. Div. No 2 Indore dated 10/06/1996

1. There will be no refund of money of to customer if laboratory unavailable to performed test in case of failure of instrument/equipment or any other reasons. Only credit noted will be issue to customer. Credit note can remitted by us in future test.

2. You can't submit/published Test certificated or its part as evidence in court matter/ paper / e-media without written permission form this office.

3. Payments are accepted either cash , by cheque /D.D./ NIFT/RTGE payable in favor of Cossimminor M C Indore. A/c No. 53003150803 State bank of India Corporation branch Indore IFSC code SBIN0030134

copy to CEO WTL Musakhedi Indore for approval please


Quality Manager
QUALITY MANAGER
WATER TESTING LABORATORY
INDORE MUNICIPAL CORPORATION
INDORE
Quality Manager